



ADDENDUM NO. 1
TO PROJECT SPECIFICATIONS FOR
RAW WATER LINE REPLACEMENT PROJECT
PROJECT NO. WTR-00016

DATE:
TO: Plan Holders
SUBJECT: Addendum No. 1
BID OPENING DATE: January 19, 2024 at 2:00 PM

This Addendum No. 1 forms a part of the Bidding and Contract Documents and modifies the Project Specifications as described below:

The following revisions shall be made to Volume 3:

- Replace 480/277V, 100 A, 3 phase Metering Panel with 120/240V, 400 A, 1 phase Metering Switchboard.
- Add 50 KVA 240-480V, 1 phase Step Up Transformer, and 150 A Disconnect Switch, and 480 V, 1-phase to 3-phase Phase Convertor.
- Locate above equipment on housekeeping pad atop a slab on grade, and on stanchions as noted on Drawings.

All other specifications are as originally described.

Please sign this addendum in the space provided and include the signed copy of the addendum with your bid documents. **NOTE THAT BID DOCUMENTS SUBMITTED WITHOUT A SIGNED COPY OF THIS ADDENDUM MAY BE CONSIDERED NON-RESPONSIVE AND MAY BE REJECTED.**

Cristal Munoz, Acting City Clerk _____, 2024

The undersigned has received and read this addendum.

Contractor Signature

Name (Printed) _____ Date _____