

**Water Treatment Plant Rehabilitation
City Project No. WTR-00017
January 10, 2024**

DESIGNER

HDR Engineering, Inc.
2365 Iron Point Road, Suite 300
Folsom, CA 95630
(916) 817-4700
(916) 817-4747 (Fax)

OWNER

City of Fort Bragg
416 North Franklin Street
Fort Bragg, CA 95437



01/10/2024

GENERAL

Scope

- A. This Addendum forms a part of the Bidding and Contract Documents and modifies the Project Specifications and Drawings described below.
- B. This Addendum consists of 3 pages and the following attachment:
 - 1. Mandatory Pre-Bid Conference Sign-In-Sheet (1 page) attached.
 - 2. Reissued Specification Section 00 73 01 – Supplementary Conditions (18 pages) attached.
 - 3. C08, Overall Ponds Improvements Plan (Updated Sheet).
 - 4. R01, Filter Treatment Units No. 1 and No. 2 Rehab Preparation Sequencing (Updated Sheet).
 - 5. R04, Filter Treatment Units No. 1 and No. 2 Rehab and Improvements Plans and Sections 1 (Updated Sheet).
 - 6. R05, Filter Treatment Units No. 1 and No. 2 Rehab and Improvements Plans and Sections 2 (Updated Sheet).

Acknowledgment

- A. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

REVISIONS TO SPECIFICATIONS

Section 00 01 00 – Advertisement for Bids

Paragraph 1 on Page 00 01 00-1

CHANGE TO READ

" Sealed Bids for the construction of the Water Treatment Plant Rehabilitation Project will be received by City of Fort Bragg at the office of 416 North Franklin Street, Fort Bragg CA, 95437 until 3:00 PM local time on **January 23rd, 2024**, at which time the Bids will be **publicly** opened and read. The Project consists of constructing upgrades and rehabilitation of the existing water treatment plant."

Section 00 21 13 – Instructions to Bidders

Article 3, Subparagraph 3.01

DELETE

Article 3, Subparagraph 3.02

DELETE

Article 5, Subparagraph 5.04 C

CHANGE TO READ

" Bidders visiting the Site are required to: (1) arrange their own transportation to the Site; and (2) each Bidder visiting the Site is responsible for providing and using its own personal protective equipment appropriate for the Site and conditions, and in accordance with posted requirements, if any. At minimum, each visitor to the Site should have an appropriate hardhat, steel-toed boots, eye and hearing protection (other than ordinary eyewear), and a high-visibility reflective safety vest. Comply with Paragraph 5.05 of these Instructions to Bidders."

Section 01 73 29 – Demolition, Cutting and Patching

Article 1.1 A.2.

ADD

" 2. Contractor is solely responsible for performing a lead analysis on existing coatings. Not all landfills accept lead containing sand blast residue. Comply with federal and state agencies and state EPA branch for safe disposal of lead containing sand blast residue."

Article 1.2 A.3.

ADD

" 3. Submit plan for worker and public safety for fugitive lead containing dust or sand blast residue."

Article 1.4 B.

ADD

" B. Contractor shall test existing coatings for lead. In the scenario that lead is found to exceed permissible exposure limits in the existing coatings, contractor is solely responsible for

providing a safe working environment for employees and other affected by the contractor's work. Refer to OSHA requirements for more information."

Section 46 07 13 – Filter Treatment Units Retrofit

Article 2.4 C.1.b.

CHANGE TO READ

"b. 100% beads – 50/50 blend of rolled/scarified."

Article 2.4 C.1.c.

DELETE

Article 2.4 C.3.

DELETE

Article 2.4 C.4.

DELETE

Article 3.3 C.2.

CHANGE TO READ

" 2. Upon completion of installation by the Contractor and certification of proper installation of the equipment by the manufacturer's factory trained service technician, the equipment shall be functionally tested under supervision of Contractor and manufacturer's factory trained service technician for a minimum of **56 HRS (including travel time)** to ensure that all clearances, vibration, tracking, and motor operation characteristics are within acceptable limits."

End of Addendum

The plans & specification associated with this Addendum can be obtained by emailing eren@fortbragg.com

